



UNIFIED FIRE AUTHORITY

PEER REVIEW FOR FIRE PROTECTION SYSTEMS

In accordance with Section 104.7.2 of the International Fire Code, the Unified Fire Authority will require a “technical opinion and report” (peer review) of all plans for the installation and/or modification of an automatic fire protection system, installation and/or modification of fire alarm and detection systems and related equipment, fire pumps and related fuel tanks, jockey pumps, controllers and related equipment, installation, modification, or removal from service of a standpipe system.

Exceptions to required peer reviews:

- 1- Installation of fire hydrants and underground fire protection supply lines.
- 2- Pre-engineered kitchen hood suppression systems.
- 3- Installation or relocation of less than 20 sprinkler heads.
- 4- Installation or relocation of less than 5 alarm/notification appliances.

The following companies and/or individuals have been approved by the Unified Fire Authority as design professionals who can conduct third party plan review. These companies/individuals cannot review plans or drawings that have been developed by their own firm or representatives. (**Companies with AFS after their name are approved to review water based automatic fire suppression systems only.**)

Craig Blue, PE Inc.

Craig Blue, P.E.

1971 West 3300 South #A
West Valley City, Utah 84119
801-886-3473
craig@cbluepe.com

Protection Consultants Inc.

Greg Jones, P.E.

1199 S. Main St #101
Centerville, Utah 84014
801-295-6070
greg@pciut.com

Spectrum Engineers

Jeff Dubois, FPE

324 S. State St. # 400
SLC, Utah 84111
801-401-8496 / 801-652-1467 cell
jdd@spectrum-engineers.com

West Coast Code Consultants

Scott W. Adams, FPE

207 East Gordon Avenue, Suite #4
Layton, Utah 84041
801-547-8133 / 435-901-2891 cell
permitdeskfire@wc-3.com

Superior Fire Protection Services (AFS Only)

Rafael Castillo

5406 W, 11000 N #510
Highland, Utah 84003
801-228-7656
rcastillo415@yahoo.com

RMC-F

Michael Christensen, P.E.

338 N 3550 W
Layton, UT 84041
801-696-8244
rmcfutah@gmail.com

RFD Engineering & Design

Robert D. Fazzio, P.E.

3668 S. Eastwood Drive
SLC, Utah 84109
801-277-4933 / 801-556-3343 cell
rdfazz@comcast.net

Impact Fire Protection Services (AFS Only)

Lynn Robinson

1823 Sorrento Drive
Woods Cross, Utah 84087
385-210-5351
impactfps@comcast.net

Please submit plans to the company of your choice. When their review and written comments are completed, submit plans to ufaplansubmittal@unifiedfire.org, or plans may be forwarded by the peer review company to the Unified Fire Authority. Any correspondence regarding plan submittal should be sent to the email listed below.

Unified Fire Authority

Stewart Gray, CFPS

Deputy Fire Marshal
4965 South Redwood Rd.
Taylorsville, Utah 84123
801-743-7233 / 801-824-3715 cell
sgray@unifiedfire.org

